



RETURN AIR SOUND TRAP DETAIL

SCALE: NONE

NOTES FOR DESIGNER: (DO NOT INCLUDE ON CONSTRUCTION DRAWINGS)

1. WHEN EDITING DETAIL TO SUIT PROJECT, ADD JOB SPECIFIC REQUIREMENTS AND DELETE ONLY THOSE PORTIONS THAT DO NOT APPLY. TO SEEK A VARIANCE FROM APPLICABLE REQUIREMENTS, CONTACT THE ESM MECHANICAL POC.
2. PROVIDE VISIBLE INSIDE SURFACES WITH FLAT BLACK FINISH WHERE REFLECTION (DARK ROOMS, ETC) OR AESTHETICS IS A CONCERN.
3. REFER TO LANL CONSTRUCTION SPECIFICATION 15080 FOR AIR DUCT BOARD SPECIFICATION.

DRAWING DEVELOPED FOR ML-3/
ML-4 PROJECTS. FOR ML-1/
ML-2, ADDITIONAL REQUIREMENTS
AND QA REVIEWS ARE REQUIRED.
(REMOVE THIS NOTE WHEN IN-
SERTED INTO A DRAWING PACK-
AGE).

2	8-13-03	U	REVISED NOTES & SOUND TRAP MATERIAL. DWG NO. WAS ST6710.	RP	AY	JM	GG	TO
1	4-30-01	U	ADDED NOTE 1 AND REVISED TO COMPLY WITH DRAWING MANUAL.	RP	RR	KB	TO	TO
NO	DATE	CLASS REV	DESCRIPTION	DWN	DSGN	CHKD	SUB	APP

**FACILITY & WASTE OPERATIONS
DESIGN ENGINEERING CONSTRUCTION SERVICES**

ENGINEERING STANDARDS MANUAL		DRAWN	R. PEARSON
		DESIGN	R. ROMERO
		CHECKED	K. BECKMAN
		DATE	6-28-99

BLDG X TA-X

SUBMITTED	APPROVED FOR RELEASE
DISCIPLINE POC: GURINDER GREWAL	STANDARDS MANAGER: TOBIN ORUCH

Los Alamos NATIONAL LABORATORY PO Box 1663
Los Alamos, New Mexico 87545

CLASSIFICATION U	REVIEWER LARRY BAYS	DATE	1 OF 1
PROJECT ID	DRAWING NO	REV	

CHAPTER 6 ST-D3040-2 2